

2010 Consumer Confidence Report for 43804112 CRIVITZ WATERWORKS

Water System Information

If you would like more information about this report, including a summary of our source water assessment please contact Glen Franzen at (715) 927-7778. The Utilities Committee meets on an as needed basis and Village Board meetings are held on the third Tuesday of each month. This report will not be mailed to customers of the Crivitz Water Utility. Copies of this report are available upon request by contacting the Crivitz Village Clerk at (715)854-2030. This report is also available on the internet at www.villageofcrivitz.com/watersewer.htm.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source id	Source	Depth (in feet)	Status
1	Groundwater	50	Active
2	Groundwater	172	Active
3	Groundwater	185	Active

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five years.

Contaminant Group	# of Contaminants
Disinfection Byproducts	2
Inorganic Contaminants	17
Microbiological Contaminants	2
Radioactive Contaminants	4
Synthetic Organic Contaminants including Pesticides and Herbicides	29
Unregulated Contaminants	20
Volatile Organic Contaminants	20

Disinfection Byproducts

Contaminant (units)	Violation	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Typical Source of Contaminant
HAA5 (ppb)	NO	60	60	1	nd- 1		
TTHM (ppb)	NO	80	0	13	1.8-13.0		By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Violation	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Typical Source of Contaminant
BARIUM (ppm)	NO	2	2	0.008	0.008	03/17/2008	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM (ppb)	NO	100	100	3	3	03/17/2008	Discharge from steel and pulp mills; Erosion of natural deposits
COPPER (ppm)	NO	AL=1.3	1.3	0.27	0 of 10 results were above the action level.	03/18/2008	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
FLUORIDE (ppm)	NO	4	4	0.7	0.7	03/17/2008	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
LEAD (ppb)	NO	AL=15	0	0	0 of 10 results were above the action level.	03/18/2008	Corrosion of household plumbing systems; Erosion of natural deposits
NICKEL (ppb)	NO	100		1.4	1.4	03/17/2008	Nickel occurs naturally in soils, ground & surface waters & is often used in electroplating, stainless steel & alloy products.
NITRATE (NO ₃ -N) (ppm)	NO	10	10	1	1		Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)	NO	n/a	n/a	5.2	5.2	03/17/2008	n/a

Radioactive Contaminants

Contaminant (units)	Violation	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	NO	15	0	1.6	1.6		Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)	NO	n/a	n/a	1.6	1.6		Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)	NO	5	0	0.6	0.6		Erosion of natural deposits

Unregulated Contaminants

Contaminant (units)	Violation	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Typical Source of Contaminant
1,2,4- TRIMETHYL- BENZENE (ppb)	NO	n/a	n/a	0.22	0.22		n/a
BROMODICHLOROMETHANE (ppb)	NO	n/a	n/a	3.3	.69-3.30		n/a
BROMOFORM (ppb)	NO	n/a	n/a	0.46	nd-.46		n/a
CHLOROFORM (ppb)	NO	n/a	n/a	8.7	.55-8.70		n/a
DIBROMOCHLOROMETHANE (ppb)	NO	n/a	n/a	2.2	.59-2.20		n/a

Volatile Organic Contaminants

Contaminant (units)	Violation	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Typical Source of Contaminant
BENZENE (ppb)	NO	5	0	0.4	nd- .4		Discharge from factories; Leaching from gas storage tanks and landfills
TRICHLOROETHYLENE (ppb)	NO	5	0	0.4	nd- .4		Discharge from metal degreasing sites and other factories

Monitoring and Reporting Violations

Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
Radioactive Contaminants	3	10/01/2010	12/31/2010

Radioactive Contaminants that were missed include: Gross Alpha, Excl. R & U; Gross Alpha, Incl. R & U; Radium, (226 + 228); Radium-228

Definition of Terms

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.